

Hydrant	Location	Comments	Date tested	Hydrant Model
H1	Ironwood E. of Lansing	Stem stuck- Unserviceable OOS	11/15/2016	
H2	Ironwood & Dale	Removed	11/15/2016	Waterous
H3	Ironwood & Ironwood Circle	Water flow and flush. Leak from Stem and stiff.	11/15/2016	Waterous
H4	Ford & Geneva	Leak above ground 5yds from hydrant. Water flow/ stiff	11/15/2016	Waterous
H5	Irowood & HWY191	No suction after closing. Top flew off while flowing. OOS	11/15/2016	Greenburg
H6	?	Not in use	11/15/2016	
H7	?	Not in use	11/15/2016	
H8	Dale	Not in use	11/15/2016	
H9	?	Not in use	11/15/2016	
H10	Ford	No water, shut off at valve OOS	11/15/2016	Waterous
H11	Ford	Stem pun, no flow OOS	11/15/2016	Waterous
H12	Frontage Rd 100yds N Geneva	Water flowed and flushed	11/15/2016	Waterous
H13	Frontage Rd & Geneva	Water flowed and flushed- stiff stem	11/15/2016	Waterous
H14	Ford & Geneva	Water flowed and flushed- <u>extremely hard to open</u>	11/15/2016	Waterous
H15	Geneva E. of Sage	Water flow and flush, no leaks. Fresh all red paint.	11/15/2016	Waterous
H16	Dale & Spiny lizard	Water flow flush, leak at 2.5, in dangerous condition OOS	11/15/2016	Eddy
H17	Geneva & Spiny lizard	Good flow, stem leak	11/15/2016	
H18	?	Removed		
H19	Dale/ middle of golf course	No water, shut off at valve	11/15/2016	Eddy
H20	1116 Geneva	Flag decorated by citizen, sleeve leak on 2.5 and stem	11/15/2016	Eddy
H21	1042 Geneva	Good flow, stiff caps, stem leak	11/15/2016	Eddy
H22	1024 Geneva	Stem wanted to snap, no flow	11/15/2016	Eddy
H23	1012 Geneva	Stem slight leak	11/15/2016	Eddy
H24	1000 Geneva	Stem leak, Leak at base	11/15/2016	Eddy
H25	Dale & Pinyon E. side	Water flow and flush, no leaks	11/15/2016	Eddy
H26	Dale & Cholla Dr. (East)	Water flow and flush, no leaks	11/22/2016	Eddy
H27	Cholla Between Lansing and Dale	Water flow and flush no leaks	11/22/2016	Waterous
H28	Cholla Dr.	Water flow and flush, no leaks	11/22/2016	Waterous
H29	Cholla & Saguario	Water flow and flush, no leaks	11/22/2016	Waterous
H30	913 Saguario	Water flow and flush, no leaks	11/22/2016	Waterous
H31	306 Dale	No hydrant present, never replaced, Cone marks spot	11/15/2016	
H32	1017 Irene	Stem frozen internal OOS	11/15/2016	
H33	Across from 239 Irene and Patio Pl	4" outlet frozen, 2" works, Heavy leak from stem when open	11/15/2016	
H34	Irene	Main no hydrant	11/15/2016	
H35	Motel	Good flow	11/15/2016	
H36	Standpipe behind proshop	Stem frozen, serious corrosion OOS	11/15/2016	
H37	Corner Irene and Sage	Good Flow	11/15/2016	
H38	186 Cholla	Leak at base, Dangerous OOS	11/15/2016	

H39	328 Sage	Water flow. Head cap cracked, stem unstable/ UNSAFE	11/15/2016	Pacific States
H40	316 Sage	Head cap cracked extensive. UNSAFE	11/15/2016	Pacific States
H41	315 Flynn Janns	OOS Stem Frozen	11/15/2016	
H42	313 Ford	Unsafe OOS	11/15/2016	
H43	304&306 Sage	Leak from stem OOS	11/15/2016	
H44	Flynn Jans	Good Flow	11/15/2016	
H45	1206 High St	Good Flow	11/15/2016	Kennedy
H46	216 Klassen Ct	Good flow, Stem needs work	11/15/2016	Pacific States
H47	213 & 215 Ford	Leak at base OOS	11/15/2016	
H48	226 Ford	Good Flow	11/15/2016	
H49	208 Klassen Ct	Bad stem OOS	11/15/2016	
H50	1207 Justin	Cracked top OOS	11/15/2016	
H51	Ford between Klassen and Justin	Good Flow	11/15/2016	Kennedy
H52	Justin by carwash	Good flow	11/15/2016	Dresser
H53	Christmas Tree and Ford	Cracked top OOS	11/15/2016	
H54	Across from Post Office on Frontage	Good Flow	11/15/2016	
H55	101 Sage and Treasure	Cracked top OOS	11/15/2016	
H56	1119 Christmas Tree & Sage	Cracked top OOS	11/15/2016	
H57	Tracy and Treasure	Leak from stem OOS	11/15/2016	
H58	Christmas Tree and Tracy	Behind Bush Leak from stem (painted red and white)	11/15/2016	
H59	1108 Justin	Stem Broke OOS	11/15/2016	Dresser
H60	West of 1017 Justin	No Flow	11/15/2016	Dresser
H61	290 Dale	Sunk in ground, good flow	11/22/2016	Dresser
H62	Dale and Justin	Hard to open, caps leak, Good flow	11/22/2016	Dresser
H63	918 Christmas Tree (Dale and Christmas)	Good Flow	11/22/2016	Pacific States
H64	Dale and Treasure	Stem Broke OOS	11/22/2016	Pacific States
H65	Behind 900 Christmas Tree	OOS	11/22/2016	Dresser
H66	127 Cholla (Cholla & Ocotillo)	Water flow	11/22/2016	Waterous
H67	Cholla Ct and Cholla	Good Flow, Stem leak	11/22/2016	Waterous
H68	Irowood & HWY191	Water flowed and Flushed-slight leak@stem	11/22/2016	Waterous
H69	927 Christmas Tree (xmas tree and Dale)	Good Flow, Stem leak	11/22/2016	Waterous
H70	913 Christmas Tree	Good Flow	11/22/2016	Waterous
H71	100 yds W. Frontage and High	Good Flow	11/22/2016	
H72	Ironwood & Shadowputt CT	Water flow and flush, no leaks.	11/22/2016	
H73	389 Shadowputt CT	Water flow and flush, no leaks	11/22/2016	
H74	918 Pinion	Water flow and flush, no leaks	11/22/2016	Waterous

Key

Good

Not good

38 not correct

36 okay